

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer I.C.Y. B.V.
Houtsaachmole 35
8531 WC Lemmer
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type	: ICY4850CM
Manufacturer's mark or name	: I.C.Y.
Reference voltage	: 230 V
Reference current	: 3 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: B
Environment classes	: M1 / E2
Temperature range	: -25 °C / +55 °C

Further properties are described in the annexes:
– Description T11823 revision 0;
– Documentation folder T11823-1.

Valid until 14 October 2031

Issuing Authority

NMI Certin B.V., Notified Body number 0122
14 October 2021

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.